



RFI # 01

Quote No. 052920RW1

13477 Louvre St
Pacoima, CA, 91331
Tel: (818) 890-0500
Fax: (818) 890-0511
www.fivestarfences.com

Attn: Tu Nguyen nguyen.tu@esuhsd.org
TO: Eastside Union School District
Tel: _____
From: Robert Wellman - (760) 296-5100 robertw@fivestarfences.com

Date: June 1, 2020
Job Address: EUSD Eastside Academy Playground
3126 East Ave, Lancaster, CA 93535
e-mail: _____

RFI-01 - Chain Link Fence Framework



Reference:

- 1). Spec Section 32 31 13, Part 2.1B: Framework specifies 2 x 6 steel tube
- 2). Spec Section 32 31 13, Part 2.2A: End, Corner, and Pull Posts: steel tube, sizes indicated on drawings.

Problem:

- 1). The thickness of 2 x 6 tubes is NOT provided.
 - A). It is assumed top rail is framework.
- 2). Sizes are NOT indicated on drawings for end, corner, and pull posts.

- 1. Gate Frame shall be Tubular steel 1-7/8" O.D., Nominal 1-1/2" dia. as drawn, not per spec. The top rail above the gate shall be Schd 40, 2" nominal dia. per detail 18/A-111
- 2. End, corner, and pull post shall be Schedule 40, nominal 2 1/2" dia. per detail 4/A-111
- 3. Clarification: Kick plate shall be provided on both sides per code

Please review and provide instruction

By: _____