



gale jordan associates, inc.

ND indicates “non-detected” for asbestos

FUNCTIONAL AREA/ NUMBERS CI21014	MATERIAL	SAMPLING AREA Tierra Bonita ES	MATERIAL LOCATION	ANALYTICAL RESULTS
Rooms 327, 328, 329				
01-03	Carpet glue – blue/black	Rooms 327, 328, 329	Floor	ND
04-06	Pebble-pattern vinyl sheet flooring (VSF) w/ glue	Rooms 327, 328, 329	Floor - Under carpet	ND
07-09	12” x 12” blue cloud vinyl floor tile (VFT) w/ mastic	Room 328 toilet/sink	Floor	ND
10-12	Cove base – light gray/gray/brown	Rooms 327, 328, 329	Wall	ND
13-15	Drywall/joint compound (new)	Room 328 toilet	Wall	ND
16-18	Drywall/joint compound	Rooms 327, 328, 329	Wall	ND
19-23	Wall texture	Rooms 327, 328, 329	Wall	ND